

Residual current circuit-breakers (RCCB)

Type A



Residual current circuit-breakers DFS 2 A Twin, 2-pole

sensitive to pulsating and alternating currents Type A, Twin-version

16 A

DFS 2 016-2/0,03-A Twin	$I_{\Delta n} = 0.03 \text{ A}$	4	1/10	09114 010	205710
DFS 2 016-2/0,30-A Twin	$I_{\Delta n} = 0.30 \text{ A}$	4	1/10	09116 010	205734

25 A

DFS 2 025-2/0,03-A Twin	$I_{\Delta n} = 0.03 \text{ A}$	4	1/10	09124 010	205642
DFS 2 025-2/0,30-A Twin	$I_{\Delta n} = 0.30 \text{ A}$	4	1/10	09126 010	205741

40 A

DFS 2 040-2/0,03-A Twin	$I_{\Delta n} = 0.03 \text{ A}$	4	1/10	09134 010	205659
DFS 2 040-2/0,30-A Twin	$I_{\Delta n} = 0.30 \text{ A}$	4	1/10	09136 010	205758

63 A

DFS 2 063-2/0,03-A Twin	$I_{\Delta n} = 0.03 \text{ A}$	4	1/10	09144 010	205666
DFS 2 063-2/0,30-A Twin	$I_{\Delta n} = 0.30 \text{ A}$	4	1/10	09146 010	205765

80 A

DFS 2 080-2/0,03-A Twin	$I_{\Delta n} = 0.03 \text{ A}$	4	1/10	09154 010	207431
DFS 2 080-2/0,30-A Twin	$I_{\Delta n} = 0.30 \text{ A}$	4	1/10	09156 010	207479

For function check without disconnecting power

Accessories: Auxiliary Switches DHI, Clamp covers KA, Software DBS, Information stickers HAS
on Page: [114](#), [115](#)

mod. widths pack. units Article No. EAN
(4014712...)

10000  25

Type A



Residual current circuit-breakers DFS 4 A Twin, 4-pole

sensitive to pulsating and alternating currents Type A, Twin-version

16 A

DFS 4 016-4/0,03-A Twin	$I_{\Delta n} = 0.03 \text{ A}$	8	1	09114 810	205819
-------------------------	---------------------------------	---	---	-----------	--------

25 A

DFS 4 025-4/0,03-A Twin	$I_{\Delta n} = 0.03 \text{ A}$	8	1	09124 810	205826
DFS 4 025-4/0,30-A Twin	$I_{\Delta n} = 0.30 \text{ A}$	8	1	09126 810	205888

40 A

DFS 4 040-4/0,03-A Twin	$I_{\Delta n} = 0.03 \text{ A}$	8	1	09134 810	205833
DFS 4 040-4/0,30-A Twin	$I_{\Delta n} = 0.30 \text{ A}$	8	1	09136 810	205895

63 A

DFS 4 063-4/0,03-A Twin	$I_{\Delta n} = 0.03 \text{ A}$	8	1	09144 810	208179
DFS 4 063-4/0,30-A Twin	$I_{\Delta n} = 0.30 \text{ A}$	8	1	09146 810	208186

For function check without disconnecting power

Accessories: Auxiliary Switches DHI, Clamp covers KA, Software DBS, Information stickers HAS
on Page: [114](#), [115](#)

10000  25

Residual current circuit-breakers (RCCB)

Type A



Residual current circuit-breakers DFS 2 A KV Twin, 2-pole

mod. pack. Article No. EAN
widths units (4014712...)

10000 25 KV G

sensitive to pulsating and alternating currents Type A, increased surge-current resistant, short-time delayed, lightning resistant, Twin-version

16 A

DFS 2 016-2/0,03-A KV Twin	$I_{\Delta n} = 0.03 \text{ A}$	4	1/10	09114 009	206526
DFS 2 016-2/0,30-A KV Twin	$I_{\Delta n} = 0.30 \text{ A}$	4	1/10	09116 009	206601

25 A

DFS 2 025-2/0,03-A KV Twin	$I_{\Delta n} = 0.03 \text{ A}$	4	1/10	09124 009	206540
DFS 2 025-2/0,30-A KV Twin	$I_{\Delta n} = 0.30 \text{ A}$	4	1/10	09126 009	206618

40 A

DFS 2 040-2/0,03-A KV Twin	$I_{\Delta n} = 0.03 \text{ A}$	4	1/10	09134 009	206564
DFS 2 040-2/0,30-A KV Twin	$I_{\Delta n} = 0.30 \text{ A}$	4	1/10	09136 009	206625

63 A

DFS 2 063-2/0,03-A KV Twin	$I_{\Delta n} = 0.03 \text{ A}$	4	1/10	09144 009	206588
DFS 2 063-2/0,30-A KV Twin	$I_{\Delta n} = 0.30 \text{ A}$	4	1/10	09146 009	206632

80 A

DFS 2 080-2/0,03-A KV Twin	$I_{\Delta n} = 0.03 \text{ A}$	4	1/10	09154 009	208131
DFS 2 080-2/0,30-A KV Twin	$I_{\Delta n} = 0.30 \text{ A}$	4	1/10	09156 009	208148

For function check without disconnecting power, non-response lag time 10 ms

Accessories: Auxiliary Switches DHi, Clamp covers KA, Software DBS, Information stickers HAS
on Page: 114, 115

Type A



Residual current circuit-breakers DFS 4 A KV Twin, 4-pole

10000 25 KV G

sensitive to pulsating and alternating currents Type A, increased surge-current resistant, short-time delayed, lightning resistant, Twin-version

16 A

DFS 4 016-4/0,03-A KV Twin	$I_{\Delta n} = 0.03 \text{ A}$	8	1	09114 809	206649
----------------------------	---------------------------------	---	---	-----------	--------

25 A

DFS 4 025-4/0,03-A KV Twin	$I_{\Delta n} = 0.03 \text{ A}$	8	1	09124 809	206656
DFS 4 025-4/0,30-A KV Twin	$I_{\Delta n} = 0.30 \text{ A}$	8	1	09126 809	206687

40 A

DFS 4 040-4/0,03-A KV Twin	$I_{\Delta n} = 0.03 \text{ A}$	8	1	09134 809	206663
DFS 4 040-4/0,30-A KV Twin	$I_{\Delta n} = 0.30 \text{ A}$	8	1	09136 809	206694

63 A

DFS 4 063-4/0,03-A KV Twin	$I_{\Delta n} = 0.03 \text{ A}$	8	1	09144 809	208193
DFS 4 063-4/0,30-A KV Twin	$I_{\Delta n} = 0.30 \text{ A}$	8	1	09146 809	216709

For function check without disconnecting power, non-response lag time 10 ms

Accessories: Auxiliary Switches DHi, Clamp covers KA, Software DBS, Information stickers HAS
on Page: 114, 115

Residual current circuit-breakers (RCCB)

mod. pack. Article No. EAN
widths units (4014712...)

Type A



Residual current circuit-breakers DFS 2 A S Twin, 2-pole

sensitive to pulsating and alternating currents Type A, selective, Twin-version

10000

40 A

DFS 2 040-2/0,30-A S Twin	$I_{\Delta n} = 0.30 \text{ A}$	4	1	09136 015	205956
DFS 2 040-2/0,50-A S Twin	$I_{\Delta n} = 0.50 \text{ A}$	4	1	09137 015	205994

63 A

DFS 2 063-2/0,30-A S Twin	$I_{\Delta n} = 0.30 \text{ A}$	4	1	09146 015	205963
DFS 2 063-2/0,50-A S Twin	$I_{\Delta n} = 0.50 \text{ A}$	4	1	09147 015	206007

80 A

DFS 2 080-2/0,30-A S Twin	$I_{\Delta n} = 0.30 \text{ A}$	4	1	09156 015	208155
DFS 2 080-2/0,50-A S Twin	$I_{\Delta n} = 0.50 \text{ A}$	4	1	09157 015	208162

For function check without disconnecting power

Accessories: Auxiliary Switches DHi, Clamp covers KA, Software DBS, Information stickers HAS
on Page: [114](#), [115](#)

Type A



Residual current circuit-breakers DFS 4 A S Twin, 4-pole

sensitive to pulsating and alternating currents Type A, selective, Twin-version

10000

40 A

DFS 4 040-4/0,30-A S Twin	$I_{\Delta n} = 0.30 \text{ A}$	8	1	09136 815	206038
DFS 4 040-4/0,50-A S Twin	$I_{\Delta n} = 0.50 \text{ A}$	8	1	09137 815	206069

63 A

DFS 4 063-4/0,30-A S Twin	$I_{\Delta n} = 0.30 \text{ A}$	8	1	09146 815	208216
DFS 4 063-4/0,50-A S Twin	$I_{\Delta n} = 0.50 \text{ A}$	8	1	09147 815	208223

For function check without disconnecting power

Accessories: Auxiliary Switches DHi, Clamp covers KA, Software DBS, Information stickers HAS
on Page: [114](#), [115](#)

Type A



Residual current circuit-breakers DFS 4 A NA, 4-pole

sensitive to pulsating and alternating currents Type A, emergency switching off function

10000

16 A

DFS 4 016-4/0,03-A NA	$I_{\Delta n} = 0.03 \text{ A}$	4.5	1/10	09114 841	225978
-----------------------	---------------------------------	-----	------	-----------	--------

25 A

DFS 4 025-4/0,03-A NA	$I_{\Delta n} = 0.03 \text{ A}$	4.5	1/10	09124 841	225992
-----------------------	---------------------------------	-----	------	-----------	--------

40 A

DFS 4 040-4/0,03-A NA	$I_{\Delta n} = 0.03 \text{ A}$	4.5	1/10	09134 841	226012
-----------------------	---------------------------------	-----	------	-----------	--------

63 A

DFS 4 063-4/0,03-A NA	$I_{\Delta n} = 0.03 \text{ A}$	4.5	1/10	09144 841	226036
-----------------------	---------------------------------	-----	------	-----------	--------

DFS with emergency stop function (variant "NA") enable connection of control elements such as push-buttons for disconnecting the RCCB in emergency situations. All devices are also available in HD design and with right-hand neutral conductor (see info pages).

Accessories: Clamp covers KA, Software DBS, Information stickers HAS
on Page: [114](#), [115](#)

Type A



Residual current circuit-breakers DRCCB 5 ST, 2-pole

sensitive to pulsating and alternating currents Type A, short-time delayed

10000

25 A

DRCCB 5 ST 025-2/0,03-A	$I_{\Delta n} = 0.03 \text{ A}$	5	1	09421 501	223233
-------------------------	---------------------------------	---	---	-----------	--------

automatic, regular self-test without any interruption to the power supply

Residual current circuit-breakers (RCCB)

mod. pack. Article No. EAN
widths units (4014712...)

Type A

Residual current circuit-breakers DRCCB 5 ST, 4-pole

sensitive to pulsating and alternating currents Type A, short-time delayed

10000    



25 A

DRCCB 5 ST 025-4/0,03-A	$I_{\Delta n} = 0.03 \text{ A}$	7	1	09 421 502	223240
-------------------------	---------------------------------	---	---	------------	--------

40 A

DRCCB 5 ST 040-4/0,03-A	$I_{\Delta n} = 0.03 \text{ A}$	7	1	09 431 502	223257
-------------------------	---------------------------------	---	---	------------	--------

DRCCB 5 ST 040-4/0,30-A	$I_{\Delta n} = 0.30 \text{ A}$	7	1	09 432 502	238312
-------------------------	---------------------------------	---	---	------------	--------

63 A

DRCCB 5 ST 063-4/0,03-A	$I_{\Delta n} = 0.03 \text{ A}$	7	1	09 441 502	223264
-------------------------	---------------------------------	---	---	------------	--------

DRCCB 5 ST 063-4/0,30-A	$I_{\Delta n} = 0.30 \text{ A}$	7	1	09 442 502	238336
-------------------------	---------------------------------	---	---	------------	--------

automatic, regular self-test without any interruption to the power supply

Type A

Residual current circuit-breakers DRCCB 5 STR, 2-pole

sensitive to pulsating and alternating currents Type A, short-time delayed

10000    



25 A

DRCCB 5 STR 025-2/0,03-A	$I_{\Delta n} = 0.03 \text{ A}$	5	1	09 421 503	223271
--------------------------	---------------------------------	---	---	------------	--------

Reclosing device with checking of the insulation resistance automatic, regular self-test without any interruption to the power supply.

Type A

Residual current circuit-breakers DRCCB 5 STR, 4-pole

sensitive to pulsating and alternating currents Type A, short-time delayed

10000    



25 A

DRCCB 5 STR 025-4/0,03-A	$I_{\Delta n} = 0.03 \text{ A}$	7	1	09 421 504	223288
--------------------------	---------------------------------	---	---	------------	--------

40 A

DRCCB 5 STR 040-4/0,03-A	$I_{\Delta n} = 0.03 \text{ A}$	7	1	09 431 504	223295
--------------------------	---------------------------------	---	---	------------	--------

DRCCB 5 STR 040-4/0,30-A	$I_{\Delta n} = 0.30 \text{ A}$	7	1	09 432 504	238367
--------------------------	---------------------------------	---	---	------------	--------

63 A

DRCCB 5 STR 063-4/0,03-A	$I_{\Delta n} = 0.03 \text{ A}$	7	1	09 441 504	223301
--------------------------	---------------------------------	---	---	------------	--------

DRCCB 5 STR 063-4/0,30-A	$I_{\Delta n} = 0.30 \text{ A}$	7	1	09 442 504	238381
--------------------------	---------------------------------	---	---	------------	--------

Reclosing device with checking of the insulation resistance automatic, regular self-test without any interruption to the power supply.